

Certificate



Functional
Safety

www.tuv.com
ID 0600000000

No.: 968/FSP 1316.01/22

Product tested	Safety Communication Profile	Certificate holder	iC-Haus GmbH Am Kuemmerling 18 55294 Bodenheim Germany
Type designation	BiSS Safety Communication Profile Rev A2		
Codes and standards	IEC 61784-3:2021 (in extracts)	IEC 61508 Parts 1-7:2010	
Intended application	The Safety Communication Profile complies with the requirements of IEC 61784-3 (in extracts) and can be used in applications up to SIL 3 according to IEC 61508.		
Specific requirements	The assessment of the correct implementation of this safety communication profile needs to be considered as part of each product evaluation. For error and diagnostic handling see the respective chapters of the BiSS Safety Implementation manual.		

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP1 V1.0:2017 in its actual version, whose results are documented in Report No. 968/FSP 1316.01/22 dated 2022-02-01. This certificate is valid only for products, which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2022-02-08

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Gebhard Bouwer

www.fs-products.com
www.tuv.com

 **TÜVRheinland**[®]
Precisely Right.